

**City of Wichita, Kansas
Americans with Disabilities Act Transition Plan**

Fire Station #4

2423 West Irving

August 2005



Prepared by

DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Fire Station #4 - August 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed <i>(Include initial)</i>
1. Restrooms	The water closet in the public unisex restroom is centered at 19-inches.	4.16	According to ADAAG, accessible water closets must be centered at 18-inches from the sidewall. Move the water closet so it is centered at 18-inches or move a portion of the sidewall so the water closet is centered at 18-inches.	L	L	M	0	\$500	Restroom Figures – Building Blocks			
2. Restrooms	The grab bars, at the water closet in the public unisex restroom, are too high measuring 37-inches to the top of each bar.	4.16.4	According to ADAAG, grab bars at water closets are required to comply with Figure 29 and mounted between 33-inches and 36-inches high. Modify the grab bars so they are mounted between 33-inches and 36-inches high.	L	L	M	0	\$400	Restroom Figures – Building Blocks			
	All other public features of this facility are fully accessible and comply with ADAAG specifications.											

Fire Station #4 - Conceptual Cost Projections

Total	\$900
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$900