

**City of Wichita, Kansas  
Americans with Disabilities Act Transition Plan**

**Fire Station #7**

2346 N. Coolidge

**August 2005**



Prepared by

**DMCG**  
**Disability Management Consulting Group L.L.C.**  
2801 Jonquil Place  
Columbia, MO 65202

In conjunction with

**The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board**

---

**City of Wichita – ADA/504 Transition Plan – Fire Station #3 - August 2005**

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Public Restroom	The grab bars, at the water closet in the Public Unisex restroom, are located too high at 37-inches.	<a href="#">4.16.4</a>	According to ADAAG, grab bars at water closets are required to comply with <a href="#">Figure 29</a> and mounted between 33-inches and 36-inches high. <b>Modify the grab bars so they are mounted between 33-inches and 36-inches high.</b>	L	L	M	<a href="#">1</a>	\$50	<a href="#">Restroom Figures – Building Blocks</a>	Lower the grab bars to 34”high from finished floor level.	12/31/16	
	All other structural features of this facility are fully accessible and comply with ADAAG specifications.											

**Fire Station #7 - Conceptual Cost Projections**

<b>Total</b>	<b>\$50</b>
<b>Year Three (High)</b>	<b>\$0</b>
<b>Year Five (Medium)</b>	<b>\$0</b>
<b>Year Ten (Low)</b>	<b>\$50</b>