

City of Wichita, Kansas
Americans with Disabilities Act Transition Plan

Reflection Park

205 East Douglas

July 2005



Prepared by

DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Reflection Park - July 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Ramp	The ramp shown in photo #2 does not provide handrails on each side.	4.8	According to ADAAG, any part of an accessible route with a slope greater than 1:20 shall be considered a ramp. If a ramp run has a rise greater than 6-inches or a horizontal projection greater than 72-inches, then it shall have handrails on both sides. The existing sidewalk has a running slope greater than 5%, measuring 6%. Provide handrails on both sides of the accessible path where the surface slope exceeds 5%.	L ®	H	L	2	\$300	Ramp Detail	Provide ADAAG compliant handrails on both sides of this ramp.	12/31/16	

Reflection Park - Conceptual Cost Projections

Total	\$300
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$300