

PROCEDURE POLICY #13

ELECTRICAL/ELEVATOR SECTION

ITEM:

CLARIFICATION REGARDING THE TYPE OF WIRING METHOD REQUIRED AND PERMITTED IN MIXED OCCUPANCIES AREAS. (**EXAMPLE:** Areas where there is a residence (**R**) and a storage business (**S**) in the same building,- such as a "live-in" residence at a U-Store type storage facility where the manager lives in part of the building and the office area is also part of the same building, but each have separate occupancy classifications).

BASIS:

To ensure that the electrical wiring meets the applicable City Ordinances and that the wiring has been installed in a safe manner.

ENFORCING AUTHORITY:

The Office of Central Inspection - Electrical/Elevator Section.

PROCEDURE:

REFERENCE: SECTION 19.12.180 OF THE CITY OF WICHITA ELECTRICAL CODE (TITLE 19).

It has been determined by this office that pursuant to the above referenced sections of the City of Wichita Electrical Code, that the wiring must be installed in an approved raceway. Type NM and NMC cable cannot be used for this application.