

**MINUTES OF MEETING OF
BOARD OF ELECTRICAL APPEALS**

December 12, 2006 - 3:00 p.m.

**OFFICE OF CENTRAL INSPECTION
CITY HALL, 455 NORTH MAIN
OCI CONFERENCE ROOM, 7th FLOOR**

Chairman Roy Meinhardt called the meeting to order at 3:00 pm, with Board members Dale Johnson, John Whittit, Harold Ragland, Dave Urban, Shane Chapman and Secretary Tom Kerschen present. Board member Jerry Addington was absent. Also present was Mike Hood and Steve Schauner.

The minutes of the November 14, 2006 meeting were read. Board member Whittit made a motion the minutes be approved as written, it was seconded by Board member Ragland and approved.

The recent examination results from Thomson Prometric for electrical examinations administered by their office for City of Wichita approved applicants were presented to the Board. The results were as follows:

APPLICANT NAME	APPLICANT NUMBER	EXAMINATION CLASSIFICATION	EXAMINATION RESULT
Philip Anders	6790	Journeyman	Failed
Paul Bohlken	3552	Journeyman	Passed
Travis Honey	9336	Journeyman	Failed
Trent Peterson	7402	Journeyman	Failed
Michael Smith	7969	Journeyman	Failed

Two (2) Master Electrician, eighteen (18) Journeyman Electrician and one (1) Elevator Mechanic examination applications were reviewed for approval to be administered the appropriate examination for certification. The results were as follows:

NAME	NUMBER	CLASSIFICATION	ACTION
Kevin Dearing	4951	Master	Approved
Elton Fritch	5246	Master	Approved
Chad Zoglmann	0641	Journeyman	Approved
Klaus Schmidt	3423	Journeyman	Approved
Dane Janney	0028	Journeyman	Approved
Dallas Leach	3943	Journeyman	Approved
Scott Lewandowski	7409	Journeyman	Approved
Nickolas Scott	1316	Journeyman	Approved

Raj Sharma	1111	Journeyman	Approved
Weston Moody	8758	Journeyman	Approved
Jonathan Girtz	2075	Journeyman	Approved
David Wiley II	7353	Journeyman	Approved
Michael Bernardo	4950	Journeyman	Approved
Jason Moran	3202	Journeyman	Approved
Gregory Covert	1666	Journeyman	Approved
Luke Warkentine	1304	Journeyman	Approved
Jeff Gulley	4372	Journeyman	Approved
Michael Smith	7969	Journeyman	Approved
Jacob Sharp	1447	Journeyman	Approved
Trent Peterson	7402	Journeyman	Approved
Kristopher Warren	3306	Elevator Mech	Approved

Under new business, Secretary Kerschen asked Mike Hood, elevator inspector, to present to the Board the problems with the installation of the Fire Controller panel at 2395 N Somerset. Mr. Hood explained that the two elevators at 2395 N Somerset were modernized in 2006 with the permit issued also in 2006 so they would be required to meet the standards in the ASME A17.1-2004 code, which requires the Fire Operation, Call Cancel, Door Open and Door Closed buttons, the additional visual signal and the operating instructions to be grouped together at the top of the main car operating panel behind a locked door. What was installed meet all the requirements except was not installed at the top of the main car operating panel.

The Board requested Secretary Kerschen to check with other jurisdictions on the interpretation of this requirement and to require Ben Boesen with Otis elevator to appear before the January Board meeting to discuss this problem.

There was no other business listed on the agenda.

Board member Whittit made a motion to adjourn. Board member Ragland seconded the motion and the meeting adjourned.

The time was 4:04 pm.

Tom Kerschen, Secretary,
Board of Electrical Appeals