

City of Wichita, Kansas
Americans with Disabilities Act Transition Plan

Lincoln Park

1323 South Topeka

July 2005



Prepared by

DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Lincoln Park - July 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Picnic Table	An accessible path of travel does not exist leading to the picnic table due to grass surfaces.	AGS APT 16.5.1 1	Technically, neither ADAAG nor the Recreational Facilities - Final Rule provide scoping for picnic tables. In addition, neither guideline provides specifications for what would constitute an accessible picnic table. However, the document titled “Accessibility Guidelines for Outdoor Developed Areas” (AGSAPT) does provide both scoping and specifications for accessible picnic tables. These Guidelines (AGSAPT) are <u>neither final rules nor enforceable</u> . Generally, we consider picnic tables and other park amenities for use by the general public to be services provided by local governments, which own or operate the park. Therefore, to ensure compliance with Title II’s program access requirements, we recommend following the scoping and specifications provided by the AGSAPT to determine the accessibility of picnic tables. According to AGSAPT, section 16.5.1.2 requires that where two or more fixed picnic tables are provided in a picnic area, at least 50 percent, but no less than two, shall comply with 16.5. Of the picnic tables required to be accessible, 40 percent, but never less than two, shall be located along an outdoor recreation access route. Place an additional picnic table along the existing sidewalk or move the existing picnic table so it is connected to the sidewalk.	L	H	M	3	\$200	AGSAPT	Provide an extra ADAAG compliant picnic table along the existing sidewalk.	12/31/16	
2. Restrooms	The men’s and women’s restrooms do not provide Braille signage at the entrance doors.	4.1.3(16) 4.30.4	ADAAG requires public restrooms to be designated with Braille, raised letters, and the symbol of accessibility, where restrooms are accessible. Provide ADAAG compliant signage at restroom entrances.	L	L	M	4 6	\$100	Signage Specifications for Permanent Rooms and Spaces	Provide ADAAG compliant Braille signage at these entrances.	12/31/16	
3. Restrooms	Pipes are exposed under the lavatory in the men’s restroom.	4.19	Pipes under lavatories are required to be insulated or otherwise configured to avoid contact. Ensure at least one lavatory complies with ADAAG specifications by wrapping the pipes with insulation.	L	H	M	5	\$15	See Attachment 4 – Lavatory Specifications for more information on accessible lavatories.	Insulate all exposed pipes under these lavatories.	12/31/16	

Lincoln Park - Conceptual Cost Projections

<i>Total</i>	<i>\$315</i>
Year Three (Low)	\$315
Year Five (Medium)	\$0
Year Ten (High)	\$0