

City of Wichita, Kansas
Americans with Disabilities Act Transition Plan

Bridgeport Park

35th Street and Ohio

July 2005



Prepared by

DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Bridgeport Park - July 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Pedestrian Paths	An accessible path of travel does not exist leading to the bleachers and accessible wheelchair seating locations do not exist.	4.1.3(19)	In places of assembly with fixed seating, accessible wheelchair locations shall comply with 4.33.2 , 4.33.3 , and 4.33.4 and shall be provided consistent with table at 4.1.3(19)(a) . At least one accessible route shall connect accessible buildings, facilities, elements, and spaces that are on the same site. Provide an accessible path to the bleachers and create at least one accessible wheelchair seating location along with at least one companion seat.	L	L	M	0	\$3,000	See Building Block 15 – Assembly Areas	?		
2. Pedestrian Paths	An accessible path of travel does not exist leading to both sides of soccer fields	4.5.1 4.1.2(2) (b)RF E	An accessible route complying with 4.3 is required to directly connect both sides of the court in court sports. In addition, accessible wheelchair seating is required to exist at team player seating areas. Provide an asphalt, concrete or rubber path of travel to each side or the soccer fields and team player seating areas	L	M	M	0	\$1,000	See The Recreational Facilities – Final Rule, Section 4.1.2(2)(b) (not enforceable)	?		

Bridgeport Park - Conceptual Cost Projections

Total	\$4,000
Year One (Very High)	\$0
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$4,000