

**City of Wichita, Kansas  
Americans with Disabilities Act Transition Plan**

**Columbine Park**

2319 Columbine-Halstead Street

**July 2005**



Prepared by

**DMCG**  
**Disability Management Consulting Group L.L.C.**  
2801 Jonquil Place  
Columbia, MO 65202

In conjunction with

**The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board**

---

City of Wichita – ADA/504 Transition Plan – Columbine Park - July 2005

Legend: Blue font identifies hyperlinked documents – Red font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Pedestrian Paths	An accessible path of travel does not exist leading to any of the play fields or any features at this park.	<a href="#">4.3.2</a> <a href="#">4.5.1</a> <a href="#">4.1.2(2)</a> <b>(b)RF</b>	At least one accessible route shall connect accessible buildings, facilities, elements, and spaces that are on the same site. Accessible routes are required to be stable, firm and slip-resistant. Create an accessible path (concrete, asphalt, rubber) of travel leading to any of the sports fields due to dirt/grass surfaces. An accessible route complying with <a href="#">4.3</a> is required to directly connect both sides of the court in court sports. Accessible wheelchair seating is required to exist at team player seating areas, such as dugouts, and an accessible route is required to connect all accessible features ( <a href="#">Recreational Facilities – Final Rule</a> (not enforceable)). <b>Provide asphalt, concrete or rubber path of travel to the sports fields, seating areas, and team player seating areas, is such areas exist. Note. Accessible routes are required to exist leading from parking, streets, sidewalks, and or transportations drop-off areas.</b>	L	H	M	<a href="#">1</a> <a href="#">2</a> <a href="#">3</a> <a href="#">4</a> <a href="#">5</a>	\$3,500	See The <a href="#">Recreational Facilities – Final Rule</a> (not enforceable)  <a href="#">New ADAAG</a>	Provide an inter-connected accessible sidewalk to all the spectator areas of these play fields as well as accessible wheelchair seating areas at these spectator areas.	12/31/16	

**Columbine Park - Conceptual Cost Projections**

Total	\$3,500
Year One (Very High)	\$0
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$3,500