


**City of Wichita, Kansas
Americans with Disabilities Act Transition Plan**

Evergreen Library

2601 N Arkansas

July 2005



DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Evergreen Library - July 2005 Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Exterior	The curb ramp, located near the bicycle rack, has steep side flares, an abrupt change in level and no detectable warning surface.	4.7	Since these curb ramps lead to a vehicular traffic way, the necessity of detectable warning surface is magnified. In addition, ADAAG requires side flares on curb ramps to be a maximum slope of 1:10. The existing side flares are over 2-times the maximum slope. Curb ramps are required to be flush with parking lots or streets and free of abrupt changes. A drop-off exists at the end of the curb ramp causing an abrupt change. Modify this curb ramp to comply with all ADAAG 4.7 specifications. (See Attachment 40 for more information regarding this barrier).	H ®	H	M	1	\$500	See Building Block 5 – Curb Ramps for additional ADAAG specifications. Detectable Warning Suspension Detectable Warning Specifications #1, #2	Remove the existing curb ramp and replace with an ADAAG compliant one complete with truncated domes detectable surface warning.	12/31/09	Under construction
2. Remaining areas	All other aspects of this facility, interior and exterior, are fully accessible and complies with ADAAG specifications.											

Evergreen Library - Conceptual Cost Projections

Total	\$500
Year Three (High)	\$500
Year Five (Medium)	\$0
Year Ten (Low)	\$0