

City of Wichita, Kansas
Americans with Disabilities Act Transition Plan
Fire Station #16

1632 N. Tyler

August 2005



DMCG
Disability Management Consulting Group L.L.C.
2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Fire Station #16 - August 2005 Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access			Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction			Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed <i>(Include initial)</i>
1. Restroom	Round door hardware exists on the entrance door to the men's/women's restroom.	4.13	According to ADAAG, any doors used by the general public in existing buildings are required to have opening hardware, which does not require tight grasping or twisting of the wrist to operate. Modify this door by replacing doorknobs with lever-type hardware or installing add-on levers.			L	M	M	1	\$15	See Attachment B – Accessible Door Hardware for information on inexpensive add-on lever handles.	Replace these round doorknobs with lever type hardware at this door.	12/31/16	07/12/07 (cmk)
	All other aspects of this facility are fully accessible and in compliance with ADAAG specifications.													

Fire Station #16 - Conceptual Cost Projections

Total	\$15
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$15