

City of Wichita, Kansas

Americans with Disabilities Act Transition Plan

Museum of World Treasures

835 E. 1st St. N.

July 2005



Prepared by

DMCG

Disability Management Consulting Group L.L.C.

2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Museum of World Treasures - July 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Exterior Ramp	Abrupt changes in level exist on the exterior wooden ramp.	4.1.2 (2) 4.5.2	According to ADAAG, changes in level up to 1/4 in (6 mm) may be vertical and without edge treatment (see Fig. 7(c)). Changes in level between 1/4 in and 1/2 in (6 mm and 13 mm) shall be beveled with a slope no greater than 1:2 (see Fig. 7(d)). Due to warping of the wooden surface, abrupt changes in level exist measuring 1-inch. Modify the ramp surface to ensure that changes in level do not exist beyond ¼-inch. Note: We also question the slip resistance of the wooden ramp surface. Generally, wooden surfaces do not meet the slip resistance coefficient defined by ADAAG.	M ®	H	M	0	\$500	ADAAG	New compliant ramp in place. <i>No action therefore needed.</i>	N/A	N/A (cmk)
2. Interior Paths of Travel	The passageway space, between the Buddha and the door, is too narrow at 30-inches.	4.3.3	According to ADAAG, the minimum clear width of an accessible route shall be 36 in (915 mm) except at doors (see 4.13.5 and 4.13.6), and other points not exceeding 24-inches in length. Move the displays or otherwise ensure the path of travel meets ADAAG specifications.	M	H	M	2	\$0		36" wide passageway in place. <i>No action therefore needed.</i>	N/A	N/A (cmk)
3. Interior Paths of Travel	The passageway space, in the Mummy alcove, narrows to 29-inches.	4.3.3	According to ADAAG, the minimum clear width of an accessible route shall be 36 in (915 mm) except at doors (see 4.13.5 and 4.13.6), and other points not exceeding 24-inches in length. Move the displays or otherwise ensure the path of travel meets ADAAG specifications.	M	H	M	3	\$0		Existing passageway space is compliant. <i>No action therefore needed.</i>	N/A	N/A (cmk)
4. Audio Display	The audio display in the Hall of Presidents is not accessible to individuals who are deaf or hard of hearing.	Title II TAM	The program access provisions of Title II require all programs and services to be accessible. Generally, audio presentations should also be provided in an alternate format at the request of individuals who are deaf or hard of hearing. Make available a printed version of the audio presentation where necessary.	H	H	M	9	\$20		Provide printed versions of the audio presentation and place them next to the TV monitors.	12/31/09	

City of Wichita – ADA/504 Transition Plan – Museum of World Treasures - July 2005

Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
5. Restrooms – 2 nd Floor	The men’s and women’s restrooms do not provide Braille signage at the entrance doors.	4.1.3(16) 4.30.4	ADAAG requires public restrooms to be designated with Braille, raised letters, and the symbol of accessibility, where restrooms are accessible. Provide ADAAG compliant signage at restroom entrances, measuring 60-inches high to the center of the sign, mounted at the latch side of the door.	L	L	M	4	\$100	Signage Specifications for Permanent Rooms and Spaces	Braille signage exists at these entrances. <i>No action therefore needed.</i>	N/A	N/A (cmk)
6. Restrooms – 2 nd Floor	Lavatories in the men’s and women’s restrooms have aprons that are too low.	4.19	Accessible lavatory aprons are required to be located at a minimum height of 29-inches. The existing lavatory aprons are too low at 27-inches. Ensure at least one lavatory in each restroom complies with ADAAG specifications.	L	H	M	5	\$250	See Attachment 4 – Lavatory Specifications for more information on accessible lavatories.	Raise these aprons by 2” so that they are 29” high from finished floor level.	12/31/16	
7. Restrooms – 2 nd Floor	In the men’s and women’s restrooms, the paper towel dispensers are located too high.	4.2.5 4.2.6 4.24	At least one of each type of dispenser is required to be accessible and must be within a maximum reach range of 54-inches where a side reach is possible and a maximum of 48-inches where only a forward reach is possible, to the highest operable part. The existing dispensers are located at 56-inches to the highest operable part. Ensure at least one paper towel dispenser in each restroom is within ADAAG specified reach ranges.	M	L	M	5	\$0	See Building Block #10 – Reach Ranges #1, #2, #3.	Lower existing paper towel dispensers to 48” from finished floor level.	12/31/11	
8. Restrooms – 2 nd Floor	The toilet seat cover dispenser in the men’s restroom is located too high.	4.2.5 4.2.6 4.24	At least one of each type of dispenser is required to be accessible and must be within a maximum reach range of 54-inches where a side reach is possible and a maximum of 48-inches where only a forward reach is possible, to the highest operable part. The existing dispensers are located at 56-inches to the highest operable part. Ensure at least one of each type of dispenser in each restroom is within ADAAG specified reach ranges.	M	L	M	7	\$0	See Building Block #10 – Reach Ranges #1, #2, #3.	Lower existing paper towel dispensers to 48” from finished floor level.	12/31/11	

Museum of World Treasures - Conceptual Cost Projections

Total	\$870
Year Three (Low)	\$350
Year Five (Medium)	\$500
Year Ten (High)	\$20